



**PUBLIC WORKS DEPARTMENT (B & R), HARYANA**

Office of Executive Engineer,  
Provincial Division,  
B&R Br., Faridabad.  
Phone - 0129-2288187  
Email - [eeepd1-faridabad@hry.nic.in](mailto:eeepd1-faridabad@hry.nic.in)



**Memo No.** 2658

**Dated** 14/03/2024

To

The Principal,  
Modern Vidya Niketan,  
Senior Secondary School,  
Sector-17 Faridabad.

**Subject:-** NOC for Building Structure Stability Safety Certificate for Modern Vidya Niketan, Senior Secondary School, Sector-17, Faridabad.

**Reference:-** Your office letter MVN/9332 dated 14.03.2024

In the connection of above cited subject, it is submitted that the above said school building is inspected by Sub Divisional Engineer, Provincial Sub Division No.3, PWD B&R Br., Faridabad along with concerned Junior Engineer on 29.04.2024. The school building having ground plus two floors. The inspection fees of site is deposited by the applicant vide GRN No.0115700189 dated 19.04.2024. Following are the features of the building observed during the inspection of the school:-

**GROUND FLOOR:-**

> At ground floor there are 19 no. classrooms, 11 no. office rooms, 02 no. store, 04 no. toilets, 01 no. entry foyer, 01 no. lift, 04 no. staircases, 02 no. lab, 01 no. library exist in the school premises.

**FIRST FLOOR:-**

> At first floor there are 17 no. classrooms, 05 no. rooms, 01 no. activity hall, 02 no. toilets, 04 staircase, 01 no. lift, 01 no. store exist in the school premises.

**SECOND FLOOR:-**

> At second floor there are 18 no. classrooms, 02 no. rooms, 04 no. lab, 04 staircases, 02 no. toilets, 01 no. lift exist in the school premises.


The building is having frame structure with column beams and R.C.C. slab & load bearing walls. The structure stability certificate has been also enclosed, which issued by Dr. Maqsd E Nazar, NNC Design International, G-70, 2nd floor, Jaswant Plaza, Near KalindiKunj, Main SaritaVihar Road, ShaheenBagh, Okhla, New Delhi on dated 05.04.2024. The fire NOC has been issued by the Assistance



Divisional Fire Officer/Fire Station Officer, Fire Station Sector-15, Faridabad Memo No.FS/2022/392 dated 09.06.2022 valid upto 08.06.2025. The hygiene certificate is also issued by O/o Civil Surgeon, Faridabad vide their office No.HHC/FBD/2024-25/18 dated 15.04.2024 valid upto 31.03.2025.

Keeping in view all the circumstances and the documents submitted by the applicant, the building is seems to be safe. The building safety certificate may be issued to the above mentioned school for the time period of one year. The periodical inspection of the school building must be ensured.

DA/Nil


  
Executive Engineer,  
Provincial Division,  
PWD B&R Br Faridabad.

Endst.No.

Dated:-

Copy of above is forwarded to the Sub Divisional Engineer, Provincial Sub Division No.3, PWD B&R Br., Faridabad for information and necessary with reference to his office Memo No. 106 dated 30.04.2024.

DA/Nil

  
Executive Engineer,  
Provincial Division,  
PWD B&R Br., Faridabad